

F I N A L R E P O R T

DITIDAHT FIRST NATION

**Assessment Studies of Water and
Wastewater Systems and
Associated Water Management
Practices at Selected
First Nation Communities**

**ASSOCIATED
ENGINEERING**



**May
2002**

004632

| | | | |
|-------------------|--------------------|--------------------|--------------|
| 99/03/01 B.Office | 0 TC/100ml NC 2 | 0 FC/100ml NC 0 | Satisfactory |
| 99/03/01 School | 0 TC/100ml NC 0 | 0 FC/100ml NC 0 | Satisfactory |
| 99/04/21 School | 0 TC/100ml NC 0 | 0 FC/100ml NC 0 | Satisfactory |
| 99/04/21 B.Office | 0 TC/100ml NC 0 | 0 FC/100ml NC 0 | Satisfactory |

Don MacVicar

1999/00/01

HEALTH CANADA
 First Nations Health Branch
 510 - 1230 GOVERNMENT ST.
 VICTORIA B.C.
 V8W 3Y2
 Tel. (604) 363-3143

OPERATOR:

Chief and Council
 Dididaht Reserve
 Box 340
 Port Alberni B.C.
 V9Y 7M7

File:151-5-1-27
 Code:

WATER SAMPLE REPORT

SOURCE: Dididaht Community System (wells)

| DATE ymd | LOCATION | CFU/100ml TOTAL COLIFORMS | | CFU/100ml FECAL | | COMMENTS |
|-------------|----------|---------------------------------|----|--------------------|----|--------------|
| | | TC | NC | TC | NC | |
| 99/08/12 | B.Office | 0 | 0 | 0 | 0 | Satisfactory |
| 99/08/12 | Store | 0 | 6 | 0 | 2 | Satisfactory |
| 99/12/06 | B.Office | 0 | 6 | 0 | 0 | Satisfactory |
| 00/03/07 | B.Office | 0 | 0 | 0 | 0 | Satisfactory |
| 00/03/07 | School | 0 | 0 | 0 | 0 | Satisfactory |
| 00/04/07 | B.Office | 0 | 0 | 0 | 0 | Satisfactory |
| 00/04/27 | B.Office | 0 | 4 | 0 | 0 | Satisfactory |
| 00/07/10 | Store | 0 | 2 | 0 | 0 | Satisfactory |
| 00/10/16 | Daycare | 0 | 4 | 0 | 0 | Satisfactory |
| 00/10/16 | B.Office | 0 | 2 | 0 | 0 | Satisfactory |
| 00/12/14 | B.Office | 0 | 0 | 0 | 0 | Satisfactory |

| | | | | | |
|-------------------|---|---|---|---|--------------|
| 01/01/08 School | 0 | 6 | 0 | 0 | Satisfactory |
| 01/01/08 B.Office | 0 | 4 | 0 | 0 | Satisfactory |
| 01/01/16 B.Office | 0 | 0 | 0 | 0 | Satisfactory |
| 01/07/26 B.Office | 0 | 2 | 0 | 0 | Satisfactory |
| 01/07/26 Café | 0 | 2 | 0 | 0 | Satisfactory |
| 01/08/07 B.Office | 0 | 0 | 0 | 0 | Satisfactory |
| 01/10/11 B.Office | 0 | 0 | 0 | 0 | Satisfactory |
| 01/10/11 Café | 0 | 0 | 0 | 0 | Satisfactory |
| 01/12/04 Daycare | 0 | 0 | 0 | 0 | Satisfactory |
| 01/12/04 B.Office | 0 | 0 | 0 | 0 | Satisfactory |
| 01/12/04 H.Centre | 0 | 0 | 0 | 0 | Satisfactory |

TC= Totl Coliforms - Limit 10
 FC= Fecal Coliforms - Limit 0
 Health Officer
 NC= Non coliforms - Limit 200

Don MacVicar
 Registered Environmental