

**ASSESSMENT STUDY OF
WATER AND WASTEWATER SYSTEMS
AND ASSOCIATED
WATER MANAGEMENT PRACTICES
AT SEMIAHMOO**

**A
REPORT
TO
INDIAN AND NORTHERN AFFAIRS CANADA
BC REGION**

** NovaTec Consultants Inc.
Environmental Engineers and Scientists**

July 2002

File No.: 1407.09/02

006069

A Management Summary
- Main Community
A no drawings

Appendix C

Water Testing Results

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 MAR 27

Requisition : 99WW041194

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name : 02J1790 - 02J1790

Site Desc : WHITE ROCK UTILITIES, SEMIAHM00 FIRST NATION,

s.19(1) WHITE ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : Fecal Coliform

Collected : 2000 MAR 22

Received : 2000 MAR 22

RESULTS

Reported on 2000 MAR 27

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		
3. MORE THAN 200 BACKGROUND COLONIES NOTED ON TOTAL COLIFORM MEMBRANE FILTER PER 100 ML		

*Resample.
PC.*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 MAR 23

HEALTH CANADA (VANCOUVER - FIRST N* - 1906
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Requisition : 99WW041201
Submitter Ref:

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name : 02J1797 - 02J1797

Site Desc : SEMIAHMOO FIRST NATION, CARVING SHED, WHITE ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : Fecal Coliform

Collected : 2000 MAR 22

Received : 2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

*Satisfactory
Results.*

PC

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 MAR 23

Requisition : 99WW041199

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

s.19(1)

Code/Name : 02J1795 - 02J1795

Site Desc : SEMIAHMOO FIRST NATION, , WHITE ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free

Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : Fecal Coliform

Collected : 2000 MAR 22

Received : 2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

*Satisfactory
Results
DC*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 MAR 23

Requisition :99WW041200

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name :02J1796 - 02J1796

s.19(1)

Site Desc :SEMIAMMOO FIRST NATION, [REDACTED], WHITE ROCK

City/Area : Type :

Source :Well

Specimen

Treatment :TREATED Ph Level :Free Chlorine Level :ppm

Nature :WATER Exams Req :Total Coliform

EHO : :Fecal Coliform

Collected :2000 MAR 22

Received :2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L:LESS THAN		

Satisfactory Results
fl

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society.

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 MAR 23

Requisition : 99WW041196

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:

757 HASTINGS ST SUITE 540

VANCOUVER BC V6C 3E6

Specimen Submitter

: 1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name : 02J1792 - 02J1792

Site Desc : SEMIAHMOO FIRST NATION, BAND OFFICE, 16049 BEACH RD., WHITE ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : : Fecal Coliform

Collected : 2000 MAR 22

Received : 2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

*Satisfactory
Results
AC*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society.

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 MAR 23

Requisition : 99WW041197

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

S.19(1)

Code/Name : 02J1793 - 02J1793

Site Desc : SEMIAHMOO FIRST NATION, [REDACTED] WHITE ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : Fecal Coliform

Collected : 2000 MAR 22

Received : 2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

*Satisfactory
Results
RL*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 MAR 23

Requisition : 99WW041198

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

: 1906-HEALTH CANADA (VANCOUVER *

s.19(1)

Site Information

Code/Name : 02J1794 - 02J1794

Site Desc : SEMIAHMOO FIRST NATION, WHITE ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : Fecal Coliform

Collected : 2000 MAR 22

Received : 2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

*Satisfactory
Results
PC*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2001 JUN 4

HEALTH CANADA (VANCOUVER - FIRST N* - 1906
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Requisition : A1WW010019

Submitter Ref:

Specimen Submitter

: 1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name : 0204311 - 0204311

Site Desc : SFN LOT 10 WELL, [REDACTED]

s.19(1)

City/Area :

Type : COM.W.S.

Source : Well

Specimen

Treatment :

Ph Level : Free

Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : PAULO

: Fecal Coliform

Collected : 2001 MAY 28

Received : 2001 MAY 29

RESULTS

Reported on 2001 JUN 4

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 24 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

006078

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2001 MAY 1

Requisition : A1WW003214

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name : 02N8820 - 02N8820

Site Desc : SFN, LOT 10, WELL, [REDACTED]

City/Area :

Type : COM.W.S.

s.19(1)

Source : Well

Specimen

Treatment : UNTREATED

Ph Level : Free

Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : PAULO

: Fecal Coliform

Collected : 2001 APR 18

Received : 2001 APR 19

RESULTS

Reported on 2001 APR 20

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1-3	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1-1	FC Count/100ml
L: LESS THAN		
3. ** PRELIMINARY REPORT **		

Reported on 2001 MAY 1

<u>Test</u>	<u>Result</u>	<u>Units</u>
4. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
5. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		
6. ** FINAL REPORT **		

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 24 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

MEDINET Reports Log Jun 5 01 04:21 am

Note: If you do not receive these reports, please give MEDINET a call at 737-1477 in Vancouver or toll free at 1-800-737-3771.

MEDINET Address: healcan FAX: 604-666-3356

1 ay 28 01 A1WW010019 /

End of MEDINET Reports

+++++

Page(s) 006081 to\à 006084

Is(are) under consultation



RESULTS OF ANALYSIS - Water

File No. J2954

Semlahm.
16120
Marine
98 03 03
16:25

Halogenated Volatiles

Bromodichloromethane
Bromoform
Chloroform
Dibromochloromethane
Total Trihalomethanes

0.0006
<0.0005
0.0496
<0.0005
0.0502

Remarks regarding the analyses appear at the beginning of this report.
Results are expressed as milligrams per litre except for pH, Colour (CU),
Conductivity (umhos/cm), and Turbidity (NTU).
< = Less than the detection limit indicated.



RESULTS OF ANALYSIS - Water

File No. J2954

Semiahm.
16120
Marine
98 03 03
16:25

Physical Tests

Colour	(CU)		5
Conductivity	(umhos/cm)		30
Total Dissolved Solids			21
Hardness	CaCO3		7.26
pH			6.79
Turbidity	(NTU)		3.4

Dissolved Anions

Alkalinity-Total		CaCO3	6
Chloride	Cl		1.7
Fluoride	F		<0.02
Sulphate	SO4		1

Nutrients

Nitrate Nitrogen		N	0.083
Nitrite Nitrogen		N	<0.001

Total Metals

Aluminum	T-Al		<0.2
Arsenic	T-As		0.0002
Barium	T-Ba		<0.01
Boron	T-B		<0.1
Cadmium	T-Cd		<0.0002
Calcium	T-Ca		2.64
Chromium	T-Cr		<0.01
Copper	T-Cu		0.02
Iron	T-Fe		0.28
Lead	T-Pb		0.002
Magnesium	T-Mg		0.16
Manganese	T-Mn		0.036
Mercury	T-Hg		<0.00005
Potassium	T-K		<2
Selenium	T-Se		<0.0005
Sodium	T-Na		3
Zinc	T-Zn		0.007

Remarks regarding the analyses appear at the beginning of this report.
Results are expressed as milligrams per litre except for pH, Colour (CU),
Conductivity (umhos/cm), and Turbidity (NTU).
< = Less than the detection limit indicated.



RESULTS OF ANALYSIS - Water

File No. J2614

		Semiahm. B.O.	Semiahm. W.A.G.
		98 02 18	98 02 18
Physical Tests			
Colour	(CU)	<5	<5
Conductivity	(umhos/cm)	498	518
Total Dissolved Solids		273	264
Hardness	CaCO3	100	98.9
pH		7.48	7.45
Turbidity	(NTU)	<0.1	<0.1
Dissolved Anions			
Alkalinity-Total	CaCO3	117	119
Chloride	Cl	69.1	72.3
Fluoride	F	0.14	0.15
Sulphate	SO4	21	21
Nutrients			
Nitrate Nitrogen	N	0.794	0.824
Nitrite Nitrogen	N	<0.001	<0.001
Total Metals			
Aluminum	T-Al	<0.2	<0.2
Arsenic	T-As	0.0110	0.0087
Barium	T-Ba	0.01	0.02
Boron	T-B	<0.1	<0.1
Cadmium	T-Cd	<0.0002	<0.0002
Calcium	T-Ca	22.4	21.9
Chromium	T-Cr	<0.01	<0.01
Copper	T-Cu	0.01	0.04
Iron	T-Fe	<0.03	<0.03
Lead	T-Pb	<0.001	0.001
Magnesium	T-Mg	10.7	10.7
Manganese	T-Mn	<0.005	<0.005
Mercury	T-Hg	<0.00005	<0.00005
Potassium	T-K	4	4
Selenium	T-Se	0.0016	0.0011
Sodium	T-Na	57	58
Zinc	T-Zn	0.020	0.011

Remarks regarding the analyses appear at the beginning of this report.
 Results are expressed as milligrams per litre except for pH, Colour (CU),
 Conductivity (umhos/cm), and Turbidity (NTU).
 < = Less than the detection limit indicated.

Page(s) 006088 to\à 006090

Is(are) under consultation

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 JUN 3

HEALTH CANADA (VANCOUVER - FIRST N* - 1906
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Requisition :A0WW006898

Submitter Ref:

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

s.19(1)

Code/Name :02J7158 - 02J7158

Site Desc :SEMIAHMOO, SURREY, WR UTILITY

City/Area : type :Public Waterworks System

Source :

Specimen

Treatment :TREATED

Ph Level :Free Chlorine Level :ppm

Nature :WATER

Exams Req :Total Coliform

EHO : :Fecal Coliform

Collected :2000 JUN 1

Received :2000 JUN 2

RESULTS

Reported on 2000 JUN 3

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L:LESS THAN		
3. MORE THAN 200 BACKGROUND COLONIES NOTED ON TOTAL COLIFORM MEMBRANE FILTER PER 100 ML		

Satisfactory Results
R.

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 24 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET ---

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 JUN 9

Requisition :A0WW007934

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

s.19(1)

Site Information

Code/Name :02J8013 - 02J8013
Site Desc :SEMIAHMCO FIRST NATION, [REDACTED], SURREY
City/Area : [REDACTED] Type :Public waterworks System
Source :

Specimen

Treatment :TREATED Ph Level :Free Chlorine Level :ppm
Nature :WATER Exams Req :Total Coliform
EHO : :Fecal Coliform

Collected :2000 JUN 7
Received :2000 JUN 8

RESULTS

Reported on 2000 JUN 9

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L:LESS THAN		

Satisfactory Results
FL

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 24 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY
Phone Number :

Printed :2000 JUN 9

Requisition :A0WW007933

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

s.19(1)

Code/Name :02J8012 - 02J8012

Site Desc :SEMIAHMOO FIRST NATION, [REDACTED], SURREY, W R
UTILITIES

City/Area : Type :Public Waterworks System

Source :

Specimen

Treatment :TREATED

Ph Level :Free Chlorine Level :ppm

Nature :WATER

Exams Req :Total Coliform

EHO : :Fecal Coliform

Collected :2000 JUN 7

Received :2000 JUN 8

RESULTS

Reported on 2000 JUN 9

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L:LESS THAN		

Satisfactory Results
PC.

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 24 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 JUN 3

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Requisition :A0WW006896

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

s.19(1)

Site Information

Code/Name :02J7156 - 02J7156

Site Desc :SEMIAHMOO, [REDACTED] SURREY, WR UTILITY

City/Area : Type :Public Waterworks System

Source :

Specimen

Treatment :TREATED

Ph Level :Free

Chlorine Level :ppm

Nature :WATER

Exame Req :Total Coliform

EHO :

:Fecal Coliform

Collected :2000 JUN 1

Received :2000 JUN 2

RESULTS

Reported on 2000 JUN 3

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L:LESS THAN		

Satisfactory Results
PC

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 24 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

006094

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 JUN 3

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Requisition : A0WW006897

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

s.19(1)

Site Information

Code/Name : 02J7157 - 02J7157

Site Desc : SEMIAHMOO, SURREY, WR UTILITY

City/Area : Type : Public Waterworks System

Source :

Specimen

Treatment : TREATED

Ph Level : Free

Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO :

: Fecal Coliform

Collected : 2000 JUN 1

Received : 2000 JUN 2

RESULTS

Reported on 2000 JUN 3

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

Satisfactory Results
AC

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 24 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

006095

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 JUN 3

Requisition :A0WW006899

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

s.19(1)

Site Information

Code/Name :02J7159 - 02J7159

Site Desc :SEMIAHMOO, [REDACTED], SURREY, WR UTILITY

City/Area : Type :Public Waterworks System

Source :

Specimen

Treatment :TREATED

Ph Level :Free Chlorine Level :ppm

Nature :WATER

Exams Req :Total Coliform

EHO : :Fecal Coliform

Collected :2000 JUN 1

Received :2000 JUN 2

RESULTS

Reported on 2000 JUN 3

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L:LESS THAN		
3. MORE THAN 200 BACKGROUND COLONIES NOTED ON TOTAL COLIFORM MEMBRANE FILTER PER 100 ML		

Satisfactory Results
R.

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 24 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 JUN 3

Requisition :AOWW006895

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name :02J7155 - 02J7155

Site Desc :SEMIAHMOO, BAND OFFICE, 16049 BEACH RD, SURREY, WR UTILITY

City/Area : Type :Public Waterworks System

Source :

Specimen

Treatment : Ph Level :Free Chlorine Level :ppm

Nature :WATER Exams Req :Total Coliform

EHO : :Fecal Coliform

Collected :

Received :2000 JUN 2

RESULTS

Reported on 2000 JUN 3

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration) L:LESS THAN	L1	FC Count/100ml
3. NO DATE COLLECTED GIVEN		

*Satisfactory
Results
R.*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET —

006097

Page(s) 006098 to\à 006098

Is(are) under consultation

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 MAR 23

Requisition : 99WW041198

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name : 02J1794 - 02J1794

s.19(1)

Site Desc : SEMIAHMOO FIRST NATION, [REDACTED], WHITE ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : Fecal Coliform

Collected : 2000 MAR 22

Received : 2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

*Satisfactory
Results
PC*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL
The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 MAR 23

Requisition :99WW041197

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name :02J1793 - 02J1793

s.19(1)

Site Desc :SEMIAMMOO FIRST NATION, [REDACTED] WHITE ROCK

City/Area : Type :

Source :Well

Specimen

Treatment :TREATED

Ph Level :Free

Chlorine Level :ppm

Nature :WATER

Exams Req :Total Coliform

EHO : :Fecal Coliform

Collected :2000 MAR 22

Received :2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L:LESS THAN		

*Satisfactory
Results
R.C.*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 MAR 23

Requisition : 99WW041196

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name : 02J1792 - 02J1792

Site Desc : SEMIAHMOO FIRST NATION, BAND OFFICE, 16049 BEACH RD., WHITE ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : : Fecal Coliform

Collected : 2000 MAR 22

Received : 2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

*Satisfactory
Results
PC*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL
The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 MAR 23

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Requisition : 99WW041200

Specimen Submitter

: 1906-HEALTH CANADA (VANCOUVER *

s.19(1)

Site Information

Code/Name : 02J1796 - 02J1796

Site Desc : SEMIAHMOO FIRST NATION, [REDACTED], WHITE ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free Chlorine Level : ppm

Nature : WATER

Exame Req : Total Coliform

EHO : Fecal Coliform

Collected : 2000 MAR 22

Received : 2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

Satisfactory Results
RL

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 MAR 23

Requisition : 99WW041199

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

s.19(1)

Code/Name : 02J1795 - 02J1795

Site Desc : SEMIAHMOO FIRST NATION, [REDACTED], WHITE ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : Fecal Coliform

Collected : 2000 MAR 22

Received : 2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

*Satisfactory
Results
DC*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 MAR 23

Requisition :99WW041201

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name :02J1797 - 02J1797

Site Desc :SENAHEMOC FIRST NATION, CARVING SHED, WHITE ROCK

City/Area : Type :

Source :Well

Specimen

Treatment :TREATED

Ph Level :Free Chlorine Level :ppm

Nature :WATER

Exams Req :Total Coliform

EHO : :Fecal Coliform

Collected :2000 MAR 22

Received :2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L:LESS THAN		

*Satisfactory
Results.*

PC.

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY
Phone Number :

Printed : 2000 MAR 27

Requisition : 99WW041194

HEALTH CANADA (VANCOUVER - FIRST NATION - 1906 SR) Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name : 02J1790 - 02J1790

s.19(1)

Site Desc : WHITE ROCK UTILITIES, SEMTAMMOO FIRST NATION,

WHITE ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free

Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : Fecal Coliform

Collected : 2000 MAR 22

Received : 2000 MAR 22

RESULTS

Reported on 2000 MAR 27

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		
3. MORE THAN 200 BACKGROUND COLONIES NOTED ON TOTAL COLIFORM MEMBRANE FILTER PER 100 ML		

*Resample.
PC.*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 MAR 23

Requisition : 99WW041195

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name : 02J1791 - 02J1791
Site Desc : SEMIAHMOO FIRST NATION, BERNARD CHARLES, 18850 BEACH RD., WHITE ROCK
City/Area : Type :
Source : Well

Specimen

Treatment : TREATED Ph Level : Free Chlorine Level : ppm
Nature : WATER Exams Req : Total Coliform
EHO : : Fecal Coliform

Collected : 2000 MAR 22
Received : 2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration) L: LESS THAN	L1	FC Count/100ml
3. MORE THAN 200 BACKGROUND COLONIES NOTED ON TOTAL COLIFORM MEMBRANE FILTER PER 100 ML		

Resample
PC

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 APR 10

Requisition : A0WW000389

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name : 02J2687 - 02J2687

s.19(1)

Site Desc : SEMIAHMOO FIRST NATION, [REDACTED]

S.F.N.,

WHITE ROCK

City/Area :

Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free

Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO :

: Fecal Coliform

Collected : 2000 APR 3

Received : 2000 APR 5

RESULTS

Reported on 2000 APR 10

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

*Resample
PL*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 48 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Science

BCCDC LABORATORY SERVICES
666 10th Avenue West
Vancouver, B.C. V6Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY
Phone Number :

Printed : 2000 APR 5

Requisition : A0WW000391

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
755 HASTINGS ST SUITE 510

HEALTH CANADA (VANCOUVER)

Case # :
Specimen # : 11

Collected : 2000 APR 3
Received : 2000 APR 5

S. aureus Results
PC

For inquiries from medical personnel regarding laboratory results, please contact the Client Services Unit.

Specimen was 48 hours in transit.

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 APR 10

Requisition :A0WW000388

HEALTH CANADA (VANCOUVER - FIELD STATION) - 1906
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name :02J2536 - 03J2536

Site Desc :SEMITAHMOO FIRST NATION, D DOLAN 18000, SYPAN, WHITE ROCK

City/Area : Type :

Source :Well

Specimen

Treatment :TREATED

Nature :WATER

Chlorine Residual :ppm
Exams Req :Total Coliform

EHO : :Fecal Coliform

Collected :2000 APR 3

Received :2000 APR 5

RESULTS

Reported on 2000 APR 10

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L:LESS THAN		

*Satisfactory results
fl.*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 48 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 APR 10

Requisition :A0WW000394

HEALTH CANADA (VANCOUVER) - FIRST NATION
707 PLANNING ST. SUITE 200
VANCOUVER BC V6C 3E5

Specimen Description

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Initials: [unclear]
Site: 1906-HEALTH CANADA (VANCOUVER * - ROCK

City/Area : Type :

Source :Well

Treatment :TREATED Ph Level :Free Chlorine Level :ppm

Nature :WATER Exams Req :Total Coliform

EHO : :Fecal Coliform

Collected :2000 APR 3

Received :2000 APR 5

RESULTS

Reported on 2000 APR 10

Test	Result	Units
1. Total Coliform (Membrane Filtration)	LI	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	LI	FC Count/100ml
L:LESS THAN		

*Satisfactory Results
PC*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 48 hours in transit

BCCDC LABORATORY SERVICES
The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 APR 10

Requisition :A0WW000389

HEALTH CANADA (VANCOUVER) - BUILDING 1906
1906-1001
VANCOUVER BC V6C 3E8

Submitter:

:1906-HEALTH CANADA (VANCOUVER) *

Site Information

Site Name : 1906 - 1001

Site Address : 1906-1001
City/Area : VANCOUVER Type : WHITE ROCK

City/Area :

Source : Well

Surface :

Treatment : TREATED

Nature : WATER

PH Level : Free Chlorine Level : ppm

Exams Req : Total Coliform

EHO : Fecal Coliform

Collected : 2000 APR 3

Received : 2000 APR 5

RESULTS

Reported on 2000 APR 10

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	11	FC Count/100ml
L: LESS THAN		

*Resamph
PK*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 48 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 APR 6

Requisition :A0WW000391

HEALTH CANADA (VANCOUVER) - DISTRICT
LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

HEALTH CANADA (VANCOUVER) - DISTRICT
LABORATORY SERVICES

:1906-HEALTH CANADA (VANCOUVER) *

Site Information

City/Area : ROCK

City/Area :
Source : Well

Type :

ROCK

Treatment : TREATED
Nature : WATER

Microbial : Coliforms
Examined Reagent : Coliforms

EHO : Fecal Coliform

Collected :2000 APR 3

Received :2000 APR 5

RECEIVED

Reported on 2000 APR 6

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	0	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	0	FC Count/100ml
L: LESS THAN		

Satisfactory Results
PC.

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 48 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 APR 6

Requisition :A0WW000392

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:

:1906-HEALTH CANADA (VANCOUVER *

Site Information

City/Area :

Source :Well

Nature :WATER

EHO :

:Fecal Coliform

Collected :2000 APR 3

Received :2000 APR 5

Reported on 2000 APR 6

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

Satisfactory Results
PC.

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 48 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number .:

Printed :2000 APR 12

Requisition :A0WW000390

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:

757 WASHINGTON ST SUITE 500

:1906-HEALTH CANADA (VANCOUVER *

Site Information

City/Area :

Type :

Nature :WATER

Stains Reg :Total Coliform

EHO :

:Fecal Coliform

Collected :2000 APR 12

Reported on

Reported on 2000 APR 12

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	0	CFU Count/100ml
2. Fecal Coliform (Membrane Filtration)	0	CFU Count/100ml
L:LESS THAN		

Satisfactory Results
PC

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 48 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY
Phone Number :

Printed :2000 APR 6

HEALTH CANADA (VANCOUVER - FIRST N* - 1906
222 WARDEN ST. SUITE 510

Requisition :AOWW000393

:1906-HEALTH CANADA (VANCOUVER *

Site Information

Code/Name : 02J2691 - 02J2691

Source : Well

EHO : Fecal Coliform

Collected :2000 APR 3

Received :2000 APR 5

Reported on 2000 APR 6

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
LESS THAN		
3. MORE THAN 200 BACKGROUND COLONIES NOTED ON TOTAL COLIFORM MEMBRANE FILTER PER 100 ML		

*Resample
PC.*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 48 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

Page(s) 006117 to\à 006118

Is(are) under consultation

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed :2000 APR 6

Requisition :A0WW000393

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
755 HASTINGS ST SUITE 540

:1906-HEALTH CANADA (VANCOUVER)

Site Information

EMP :

Water Coliform

Collected 10/10 APR 7

1. Total Coliform (Membrane Filtration)
2. Fecal Coliform (Membrane Filtration) LI 100 CFU/100ml
LESS THAN
3. MORE THAN 200 FISHBONE COLIFORMS ON TOTAL COLIFORM MEMBRANE
FILTER PER 100 ML

*Resample
Rc.*

For inquiries from medical personnel regarding laboratory results,

Specimen was 43 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 10th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 APR 12

Requisition : AOWW000390

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540

: 1906-HEALTH CANADA (VANCOUVER -

BAC

Medical Microbiology

1. Faecal Coliforms (MFC) 100000
2. Faecal Coliforms (MFC) 100000

Satisfactory Results
PC

For inquiries from medical personnel regarding laboratory results, -

Specimen was 48 hours in transit.

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Sixty

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY
Phone Number :

Printed :2000 APR 6

Requisition :A0WW000392
HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540

:1906-HEALTH CANADA (VANCOUVER -

Collected :2000 APR 3
Received :2000 APR 5

Satisfactory Results
PC

For inquiries from medical personnel regarding laboratory results, *

Specimen was 48 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services

HEALTH

006121

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 APR 10

Requisition : A0WW000394

HEALTH CANADA (VANCOUVER - FIRST N* - 1906 Submitter Ref:
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

: 1906-HEALTH CANADA (VANCOUVER, *

s.19(1)

Site Information

Code/Name : 02J2692 - 02J2692

Site Desc : SEMIAHMOO FIRST NATION, [REDACTED], S.F.N., WHITE

ROCK

City/Area :

Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free

Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO :

: Fecal Coliform

Collected : 2000 APR 3

Received : 2000 APR 5

RESULTS

Reported on 2000 APR 10

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

Satisfactory Results
PC

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 48 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 APR 10

HEALTH CANADA (VANCOUVER - FIRST N* - 1906
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Requisition : A0WW000395

Submitter Ref:

Specimen Submitter

: 1906-HEALTH CANADA (VANCOUVER *

s.19(1)

Site Information

Code/Name : 02J2693 - 02J2693

Site Desc : SEMIAHMOO FIRST NATION, [REDACTED], S.F.N., WHITE
ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free

Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : Fecal Coliform

Collected : 2000 APR 3

Received : 2000 APR 5

RESULTS

Reported on 2000 APR 10

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

*Satisfactory
Results
RC*

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 48 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services

MEDINET

BC Centre for
Disease Control
Society

BCCDC LABORATORY SERVICES
655 12th Avenue West
Vancouver, B.C V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 APR 10

HEALTH CANADA (VANCOUVER - FIRST N* - 1906
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Requisition : A0WW000388

Submitter Ref:

Specimen Submitter

:1906-HEALTH CANADA (VANCOUVER *

s.19(1)

Site Information

Code/Name : 02J2686 - 02J2686

Site Desc : SEMIAHMOO FIRST NATION, [REDACTED], WHITE ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free

Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO : Fecal Coliform

Collected : 2000 APR 3

Received : 2000 APR 5

RESULTS

Reported on 2000 APR 10

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		

Satisfactory Results
fl.

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 48 hours in transit

BCCDC LABORATORY SERVICES

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET

BC Centre for
Disease Control
Society

PROVINCIAL LABORATORY
B.C. CENTRE FOR DISEASE CONTROL
655 12th Avenue West
Vancouver, B.C. V5Z 4R4

Fax: (604)660-6073

ENVIRONMENTAL
BACTERIOLOGY

Phone Number :

Printed : 2000 MAR 23

Requisition : 99WW041195

HEALTH CANADA (VANCOUVER - FIRST N* - 1906
757 HASTINGS ST SUITE 540
VANCOUVER BC V6C 3E6

Specimen Submitter

: 1906-HEALTH CANADA (VANCOUVER *

s.19(1)

Site Information

Code/Name : 02J1791 - 02J1791

Site Desc : SEMIAHMOO FIRST NATION, [REDACTED], WHITE ROCK

City/Area : Type :

Source : Well

Specimen

Treatment : TREATED

Ph Level : Free

Chlorine Level : ppm

Nature : WATER

Exams Req : Total Coliform

EHO :

: Fecal Coliform

Collected : 2000 MAR 22

Received : 2000 MAR 22

RESULTS

Reported on 2000 MAR 23

<u>Test</u>	<u>Result</u>	<u>Units</u>
1. Total Coliform (Membrane Filtration)	L1	TC Count/100ml
2. Fecal Coliform (Membrane Filtration)	L1	FC Count/100ml
L: LESS THAN		
3. MORE THAN 200 BACKGROUND COLONIES NOTED ON TOTAL COLIFORM MEMBRANE FILTER PER 100 ML		

Resample
PC

For inquiries from medical personnel regarding laboratory results,
please contact the Central Inquiry Line at 604-660-5100.

Specimen was 0 hours in transit

THE B.C. CENTRE FOR DISEASE CONTROL

The Province's centre of expertise in communicable disease control and provider of specialty health support services.

MEDINET